

Jane Wondergem

From: Rich Calbi
Sent: Wednesday, November 23, 2022 3:15 PM
To: Jane Wondergem
Cc: William Bierwas
Subject: RE: Les Dann, LLC, 246-264 S. Broad St.

Jane,

The water department has two comments:

- Provision for the existing fire service connection to the new building need to be addressed.
- All existing connections should be cut and capped at the street main.

The applicant can contact Superintendent, William Bierwas, with any questions.

Thank you,

Rich C.



Richard Calbi Jr. P.E., P.D.

Director of Operations
111 North Maple Avenue
Ridgewood, N.J. 07450
(201) 670-5521 x2272
rcalbi@ridgewoodnj.net



LIKE US ON

@RidgewoodWater

This communication is intended only for the use of the named addressee and may contain information which is privileged, confidential and exempt from disclosure under applicable law. If the reader of this communication is not the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you have received this communication in error, please notify us immediately by email and delete the original message.

For Official Business Use Only - Official email of the Village of Ridgewood, NJ

From: Jane Wondergem <jwondergem@ridgewoodnj.net>
Sent: Tuesday, November 22, 2022 3:32 PM
To: Chris Rutishauser <crutishauser@ridgewoodnj.net>; Anthony Merlino <amerlino@ridgewoodnj.net>; Paola Perez <pperez@ridgewoodnj.net>; Jacqueline Luthcke <jluthcke@ridgewoodnj.net>; William Amoruso <wamoruso@ridgewoodnj.net>; Forest Lyons <flyons@ridgewoodnj.net>; John Young <jyoung@ridgewoodnj.net>; Rich Calbi <rcalbi@ridgewoodnj.net>; Marissa Granovsky <mgranovsky@ridgewoodnj.net>; William Palumbo <wpalumbo@ridgewoodnj.net>